## ADDENDUM #1 MLEA Scenario Building

Owner: Architect:

Montana State University

Facilities Management

Owner Rep: Donny Beebe

Bozeman, Montana 59718

Reprint Management BBG

Project Manager, PDC Project Architect: Thomas Brown

## **NOTICE TO BIDDERS**

This Addendum is issued pursuant to the Instructions to Bidders. This Addendum serves to clarify, revise, and supersede information in the Contract Documents and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.

The Bidder shall acknowledge receipt of this Addendum on the Bid Form.

The Date for receipt of bids is unchanged.

## **BIDDER QUESTIONS**

**Question 1** Would the existing slab need saw cutting along inside edge of posts to provide a flat continuous finish at the addition?

Answer 1 Yes, this will be required for removing posts along that elevation and cutting out the slope at the overhead door. Please see the updated demo sheet note for saw cut,

D1.01 – Revision 1 bubble.

**Question 2** Can the removed existing siding be reused?

Answer 2 Yes, please see the updated demo sheet note for salvage and reuse of existing siding,

roofing, and trims that are not damaged, D1.01 – Revision 1 bubble.

**ATTACHMENTS** 

DRAWINGS: Revised- D1.01 sheet

\*\*\*END OF ADDENDUM\*\*\*

